


ELEVATION OF PILLER WITHOUT BOLT OF MKD - "R" (QTY- 12 NOS.)

700

BOLT/TOR 12mmX150mm LONG.





700

ELEVATION OF PILLER WITHOUT BOLT OF MKD - "S" (QTY- 3 NO.)

Notes:-

- All dimensions are in milimeters.
- Cooling tower will be assembled on isa-50x50x6 frame fixed on RCC pillar the frame is under purchasers scope unless othervise stated.
- Makeup and quickfill connection shall be provided with thread connections as per is-544-1955. Inlet & outlet connection shall be provided without flange.
- 4
- RCC basin and RCC pillers 250x250x700 ht. And Ø12 x 150 long bolts/tor are under purchaser scope.
- 10 mm hole at the distance of 125mm on the peripheral of ISA of the base frame shall be provided by purchaser
- Location of outlet connection will be as per the site requirement.
- \$\psi 12x150 long bolts/tor shall be grouted in the centre of outer columns as shown in the drawing.
- All pictures shown are for illustration purpose only and may differ from the actual cooling tower model

4960 4694	4944	5210	620	587	1240	2347 2100	2100
	DESCRIPTION	NOL			MARK	SIZES	83
INLET PIPE CONNECTION	NNECTION	N			Α	150 X 2 NOS)S.
OUTLET PIPE CONNECTION	CONNECTI	ON			В	200 X 1 NO).
DRAIN & OVERFLOW CONNECTION	RFLOW CC	NNECTIO	Ż		С	50 EACH	
MAKEUP AND QUICKFILL CONNECTION	QUICKFIL	T CONNE	CTION		D	40 EACH	
LENGTH OF COOLING TOWER	DOLING TO)WER			Е	4960	
WIDTH OF COOLING TOWER	OLING TO	WER			F	4694	
FAN DIA AND NOS	NOS.				P	Ø2100 X 2 Nos.	Nos.

OPERATING WEIGHT (KG.)

7200

Degi.

0	=	
COMPANY: Delta Cooling Towers P. Ltd	G.A OF DRG. OF COOLING TOWER MODEL NO. 6450 SERIES - DFC 60	NOT TO SCALE / DO NOT SCALE DRAWING
ers P. Ltd	TOWER MODEL NO. 6450 FC 60	JOB NO

mOnContract.com	(PH - 011-27495801/02/03) EMAIL- mail@delta.cool	Delta Cooling Towers P. Ltd
REV :- 12/2017	MAIL- mail@delta.cool	owers P. Ltd