



700

BOLT / TORR 12mmX150mm LONG.

## Notes:-

ELEVATION OF PILLER WITHOUT BOLT OF MKD - "S" (QTY-1 NO.)

700

- All dimensions are in milimeters.
- 2. Cooling tower will be assembled on isa-50x50x6 frame fixed on RCC pillar the frame is under purchasers scope unless othervise stated.
- 3. Makeup and quickfill connection shall be provided with thread connections as per is-544-1955.
- 4. Inlet & outlet connection shall be provided without flange.
- 5 RCC basin and RCC pillers 250x250x700 ht. And Ø12 x 150 long bolts/tor are under purchaser scope.
- 6 10 mm hole at the distance of 125mm on the peripheral of ISA of the base frame shall be provided by purchaser
- 7. Location of outlet connection will be as per the site requirement.
- Ø12x150 long bolts/tor shall be grouted in the centre of outer columns as shown in the drawing.

All pictures shown are for illustration purpose only and may differ from the actual cooling tower model

3738	3432	3682	3988	623	572	1869		1716	1200
		DESCRIPTION	NOL		×	MARK		SIZES	S
INLET	PIPE CON	INLET PIPE CONNECTION	Z			Α	150	150X 2 NOS	•
OUTLI	ET PIPE C	OUTLET PIPE CONNECTION	ON			В	200	200 X 1 NO.	
DRAIN	\& OVER	DRAIN & OVERFLOW CONNECTION	INNECTIO	)N		С	50	50 EACH	
MAKE	UP AND	MAKEUP AND QUICKFILL CONNECTION	L CONNE	CTION		D	25	25 EACH	
LENG:	TH OF CO	LENGTH OF COOLING TOWER	)WER			E	3738	88	
WIDTE	1 OF COO	WIDTH OF COOLING TOWER	WER			F	3432	32	
FAND	FAN DIA AND NOS.	OS.				P	<b>Ø</b> 1	<b>ð1200 X 2 Nos</b>	Vos.
OPER/	ATING WI	<b>OPERATING WEIGHT (KG.)</b>	1.)				3600	)0	

DesignOnContract.com

REV: 12/2017